



# ASHRAE Chapter Technology Awards



## **Application Form:**

### **Sarah E. Goode STEM Academy**

7651 South Homan Avenue  
Chicago, IL 60652

Owner: Public Building Commission of Chicago

Architect: STR Architects / Nia Architects

Engineer of Record: dbHMS

**Illinois Chapter, Region VI**

# CHAPTER/REGIONAL TECHNOLOGY AWARD - SHORT FORM

**1. Category (Check one and indicate New or Existing, if applicable)**

Commercial Buildings  New or  Existing

Institutional Buildings:

Educational Facilities  New or  Existing

Other Institutional  New or  Existing

Health Care Facilities  New or  Existing

Industrial Facilities or Processes  New or  Existing

Public Assembly  New or  Existing

Residential (Single and Multi-Family)

**2. Name of building or project:** \_\_\_\_\_

City/State: \_\_\_\_\_

**3. Project Description:** \_\_\_\_\_

Project Study/Design Period: \_\_\_\_\_ to \_\_\_\_\_  
Begin date (mm/yyyy) End date (mm/yyyy)

Percent Occupancy at time of submission: \_\_\_\_\_

**4. Entrant (ASHRAE member with significant role in project):**

a. Name: \_\_\_\_\_  
Last First Middle

Membership Number: \_\_\_\_\_

Chapter: \_\_\_\_\_

Region: \_\_\_\_\_

b. Address (including country): \_\_\_\_\_

City State Zip Country

c. Telephone: (O) \_\_\_\_\_ d. Email: \_\_\_\_\_

e. Member's Role in Project: \_\_\_\_\_

f. Member's Signature:  \_\_\_\_\_

**5. Engineer of Record:** \_\_\_\_\_

By affixing my signature above, I certify that the information contained in this application is accurate to the best of my knowledge. In addition, I certify that I have discussed this entry with the owner and have received permission from the owner to submit this project to the ASHRAE Technology Awards Competition.

Sarah E. Goode STEM Academy is a 212,000 square-foot facility with a gymnasium, pool, dining room, kitchen, classrooms, library, art rooms, music rooms, and administrative offices. The high school is the first LEED Platinum High School in Illinois and the first Chicago Public High School with a ground source heat pump system. Sustainable features include a green roof, community garden, rain garden and permeable pavers for the parking surface. The project is LEED Platinum certified.

**Energy Efficiency**

The building is designed to exceed the ASHRAE 90.1-2004 Appendix G Baseline by 40% and achieved 9 points under LEED v2 EA Credit 1. Table 1 provides the predicted energy performance.

<b>Table 1: Summary of Energy Performance</b>			
	Energy Model		Baseline
Electricity Consumption	1,275,498 kWh		2,198,710 kWh
Gas Consumption	199,000 therms		252,400 therms
Total Consumption	6,342 MMBtu		10,026 MMBtu

The HVAC system consists of distributed, packaged ground-source heat pumps served by a ground heat-exchanger comprised of 170 boreholes at 450 feet deep spaced 20 feet on center. Outside air is ducted directly to the heat pumps from a central, dedicated outside air ground-source heat pump with an integral enthalpy wheel. Custom ground-source heat pumps also serve the gymnasium and pool dehumidification. High-efficiency condensing boilers provide back-up heat.

The solar thermal service water heating system consists of 19 roof mounted evacuated tube collector panels and 800 gallons of storage with external plate and frame heat exchangers. The system provides 18% of the pool and domestic water heating energy over the course of a typical year.

Energy efficient lighting is provided with fixture integral daylight dimming controls in the classrooms and select common spaces.

**Indoor Air Quality**

The system outside air intake exceeds the ASHRAE 62.1-2007 requirements by 30%. The required out-door air intake was calculated via the system Ventilation Rate Procedure for a multi-zone recirculating systems where applicable with system efficiencies ranging from 0.7-0.8. Exhaust requirements were determined per ASHRAE 62.1-2007 and local code.

CO2 sensors monitor CO2 concentrations in densely occupied spaces. Demand control ventilation is provided for units with CO2 monitoring. Airflow monitoring stations are provided for all unit outside air intakes.

**Innovation**

Sarah E. Goode STEM Academy is the only ground-source heat pump system in the Chicago Public School district.

Each packaged heat pump is provided with a three way condenser valve and a small circulating pump. This allows condenser water control with a single-pass condenser water loop significantly saving on piping cost and pump energy. Designed custom for this project, the condenser water piping arrangement is now offered as a standard accessory by the heat pump manufacturer.

The heat pumps are located in closets in each classroom. The design team worked carefully with acoustician to achieve the classroom design criteria of 35 dBA (NC-30). Measures to reduce heat pump noise included closet sound insulation, heat pump mounting vibration isolation, dual stage compressors and ECM motors with soft-start programming.

**Operation & Maintenance**

The heat pumps are floor mounted and easily accessible for filter changes and compressor maintenance. All major equipment excluding the solar collectors is located indoors. The absence of a cooling tower significantly reduces water treatment requirements and eliminates the need for system winterization.

**Cost Effectiveness**

The building is based on a prototype design with a centralized VAV system, boilers, and water-cooled chiller. Three other schools on Chicago’s South side were based on the same prototype and used the prototype system. Sarah E. Goode STEM Academy saved an average of \$7 million in installed costs over the three other prototypes due to the packaged ground-source HVAC system. The additional cost of the ground heat-exchanger was significantly off-set by a reduction in the building height due to smaller ductwork and the removal of the mechanical pent-house. The project was actually rejected for a federal grant as it cost less than the conventional system. In addition to the capital cost savings, the ground-source heat pump system reduced the HVAC operating energy by an estimated 20%.

**Environmental Impact**

Table 2 summarizes the predicted reduction in the building CO<sub>2</sub> emissions relative to the ASHRAE 90.1-2004 Appendix G Baseline:

<b>Table 2: CO2 Reduction from ASHRAE 90.1-2004 Baseline</b>			
	Energy Model	Baseline	Reduction
LBs CO2 Emitted*	2,197,038	3,681,246	1,484,209
Estimated Building Energy Intensity (kBtu/sf)	32	51	19

\*1.54 lbs CO<sub>2</sub>/ kWh and 116.97 lbs CO<sub>2</sub>/MMBtu- EPA 2009